

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235344  
Address: 2101 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Thursday, January 25, 2024

Corrective Action Required:

1	Misc	-Secure MC cables within 12" of j-boxes in men restroom and space at east of building -Complete mechanical and fire sprinkler -Need access to the women restroom
---	------	--

**Comments:**