

January 25, 2024

Robb Popp  
City of Lee's Summit  
220 SE Green Street  
Lee's Summit, MO 64063

RE: Post Installed Anchors at Pallet Rack Base  
Midwest Distribution  
1220 NW Main Street, Lee's Summit Missouri

Dear Robb,

PMA Engineering has reviewed the substitution of 1/2" diameter DeWalt Power Stud+SD1 anchors in lieu of the 1/2" diameter Hilti KWIK-X Screw anchors specified on the Contract Documents prepared by PMA Engineering dated 10/26/2023. Based on testing results provided by the manufacturer (DeWalt Anchoring and Fastening Systems) which utilized the field installed anchor spacing, it is our opinion that these anchors are acceptable.

Please contact me if you have any questions or comments related to this issue.

Regards,

PMA Engineering

David M. McNaghten, P.E. S.E.  
President Emeritus

cc: Randy Buck  
Scott Coryell  
Greg Mitchem  
Steve Edwards

