

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234774

Address: 3734 SW MARYVILLE PL, LEES SUMMIT, MO 640823736 SW MARYVILLE PL, LEES SUMMIT, MO
640823738 SW MARYVILLE PL, LEES SUMMIT, MO 640823740 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Residential	Kyle Beard	Failed	Friday, January 26, 2024

Corrective Action Required:

1	Miscellaneous Correction	3734 Gas line does not have the bonding wire attached
		3740 Gas gauge is at 0 PSI

Comments: