



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20114198, Building Permit - Commercial  
Address: 838 SW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Mechanical Inspection - Residential</b>	John Borns	Partial	Tuesday, August 09, 2011

Partial Correction  
1

RTU's TO BE ADDRESS-LABELED WITH CORRESPONDING  
DESIGNATIONS REFLECTED IN ELECTRICAL SERVICE PANEL(S);  
ELECT RECEPT REQUIRED WITHIN 10 METERS OF RTU's

**Comments:**