

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234721

Address: 2002 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822004 SW HOLDBROOKS DR, LEES SUMMIT,  
MO 640822006 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822008 SW HOLDBROOKS  
DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Partial	Monday, January 29, 2024

Informational:

1 Misc

1-29-24 Dustin A, This is for units 2008,2006,2004, and 2002. SW is formed and aggregate is compacted . Slopes are in compliance approved to pour white cure will need to be applied

**Comments:**