

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235123
Address: 2772 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, January 29, 2024

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | <ul style="list-style-type: none">- Post Address- Fire block floor penetration at kitchen- Nail 3-stud pack together 2x6" at main floor stairs- Solid block sheathing breaks at bedroom 2 sides of windows- Protect wiring within 6' of attic access secured floor- Can not inspect deck roof |
|---|------|--|

Comments: