



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

Prevention Division
(816)969-1300

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20236408	Date:	January 30, 2024
Project Title:	GAMEDAY MEN'S HEALTH	Applicant:	
Location:			
200 NE MISSOURI RD, Unit:303, LEES SUMMIT, MO		GENERAL FIRE SPRINKLER COMPANY LLC	
64086		11000 LAKEVIEW AVE #100	
Type of Work:		LENEXA, KS 66219	
Occupancy Group:	B	Primary:	(913) 390-1105
Description:	CHANGE OF TENANT FOR		
MEDICAL OFFICE			
Construction Type:	Type IIB (Unprotected)		
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Jim Eden

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

A visual inspection will be completed at the occupancy inspection.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.