

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236250
Address: 2083 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Robb Popp	Failed	Tuesday, January 30, 2024

Corrective Action Required:

1	Misc	-Have engineer address pier pads in rec room not fully bearing on soil. Pads are formed over the excavated bank. This footing is not approved to pour
---	------	---

Comments: