## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20230107

Address: 1501 NE US 40 HWY, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Tuesday, January 30,

Commercial 2024

Corrective Action Required:

1 Misc -Underground electrical raceway to signage shall be min 18" below grade

\*\*Need to verify burial depth of raceway

Comments: