

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20233152

Address: 451 SE OLDHAM PKWY, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary Sewer Construction Inspection</b>	Patrick Schonfeldt	Partial	Wednesday, January 31, 2024

Informational:

1	Misc	1-31-24 PS Inspected line from sewage injector pump at building B to cleanout at building A per plans. Approved to backfill line. Recall for inspection of pump after placement and connection of oil/grease interceptor to pump
---	------	--

**Comments:**