



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRRES20113266, Building Permit - Residential
Address: 1308 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Khanh Nguyen	Passed	Wednesday, August 10, 2011
Sewer Service Inspection - Residential	Khanh Nguyen	Partial	Wednesday, August 10, 2011

Comments:CANNOT LOCATE THE GROUNDING REBAR @ SE CORNER AS NOTED AT FOOTING INSPECTION