

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20235123  
Address: 2772 SW 11TH ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, January 31, 2024

Corrective Action Required:

1	Misc	- Post Address - Fire block floor penetration at kitchen - Nail 3-stud pack together 2x6" at main floor stairs - Solid block sheathing breaks at bedroom 2 sides of windows - Protect wiring within 6' of attic access secured floor - Can not inspect deck roof
---	------	---

Corrective Action Required:

2	Misc	INSPECTION DENIED EROSION CONTROL NOT CORRECTED  NO POSTED ADDRESS
---	------	--

Comments: