

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20225393  
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mitchell Schwarz	Failed	Thursday, February 01, 2024

Corrective Action Required:

1	Misc	Second floor bath only. Install bath vents
---	------	--------------------------------------------

Corrective Action Required:

2	Misc	First floor -Complete day room -Complete hallway -gym full unused MC connection at box Inspected. -dayroom border of drop ceiling okay -bathrooms okay -conference room border of drop ceiling okay -captain office border of drop ceiling okay -covered patio on W side okay -east patio/entrance okay -conference room okay
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Informational:

3	Misc	2nd floor -203 to be completed -202 okay -hall okay -213 close boxes and fill unused knockout.
---	------	------------------------------------------------------------------------------------------------------------

- 212 okay
- 211 okay
- 210 okay
- 209 okay
- 205 okay
- 207 to be completed
- 208 okay
- hall duct work To be seal
- ceiling space above stair ok

**Comments:**