

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236052

Address: 3710 SW MARYVILLE PL, LEES SUMMIT, MO 640823712 SW MARYVILLE PL, LEES SUMMIT, MO
640823716 SW MARYVILLE PL, LEES SUMMIT, MO 640823718 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Kyle Beard	Passed	Thursday, February 01, 2024

Comments: