

DEVELOPMENT SERVICES

Residential Plan Review

February 01, 2024

TRUMARK HOMES, LLC
PO BOX 728
BLUE SPRINGS, MO 64013
(816) 564-5613

Permit No: PRRES20240344
Plan Name:
Project Address: 2779 SW 11TH TER, LEES SUMMIT, MO 64081
Parcel Number: 260104
Location:
Type of Work: NEW SINGLE FAMILY
Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY
Description: NEW HOUSE. FINISHED/UNFINISHED BASEMENT. WALKOUT BASMENT. COVERED/UNCOVERED DECK.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Andrea Sessler **Approved**

Residential Plan Review Reviewed By: Andrea Sessler **Rejected**

1. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

Planning Review RES Reviewed By: Shannon McGuire **Pending**

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	
Residential, Decks	154
Residential, Finished basements	501
Residential, garage	620
Residential, Living Area (Not Finished Basement)	2128

Residential, Un-Finished basements		647	
Roofing Material		Number of Bathrooms	3.5
Number of Bedrooms	5	Number of Stories	2
Number of Living Units	1	Total Living Area	2629