CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234774

Address: 3734 SW MARYVILLE PL, LEES SUMMIT, MO 640823736 SW MARYVILLE PL, LEES SUMMIT, MO

640823738 SW MARYVILLE PL, LEES SUMMIT, MO 640823740 SW MARYVILLE PL, LEES

SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

All Rough Inspection - Kyle Beard Passed Friday, February 02,

Residential 2024

Informational:

1 Miscellaneous Portal inspections passed. Okay to cover

Correction

Corrective Action Required:

2 Miscellaneous 3740 SW Maryville. All rough (3)

Correction

Bathroom 2 needs a taller nail plate at plumbing on west wall bottom plate

3738

Bathroom 2 needs a taller nail plate installed at plumbing west wall at

bottom plate

3736

BOCA plate is needed in bathroom 2 at sole plate for plumbing along west

wall

3734

BOCA plate needed in bathroom 2 at DEV line

Comments: