CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20213072

Address: 1225 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Friday, February 02,

Residential 2024

Corrective Action Required:

1 Misc -Provide landscaping at rear of lot (3 min 8 ft tall evergreen trees, 2

ornamental trees of min 3" caliper, and 3 bushes-all located within 20 ft of

rear property line)

-If lawn irrigation is installed, obtain lawn irrigation permit and submit

backflow valve test report to city

-As-graded plot plan is required. Inspection of the plot grading is required

prior to sodding

-Final grade per approved as-graded plot plan (not yet submitted), lay sod.

Also make sure to clean debris out from the storm inlet

-Provide sewer tracer wire port at grade

-Provide a missing wall receptacle at west master bedroom wall

-Provide a receptacle at each cabinet wall spaces adjacent to fireplace

Comments: