

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20216099  
Address: 4728 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Partial	Friday, February 02, 2024

Corrective Action Required:

1	Misc	Deck has been enlarged from approved plan. The enlarged deck joists on the north side are way over-spanned. Submit revised plan for the deck
		**The three 24" diameter piers on original plan and two new piers are ok to pour

**Comments:**