

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225393
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mitchell Schwarz	Not Ready	Friday, February 02, 2024

Corrective Action Required:

1	Misc	Second floor bath only. Install bath vents
---	------	--

Corrective Action Required:

2	Misc	Remove drop ceiling tiles for inspection First floor -Complete day room -Complete hallway -gym full unused MC connection at box Inspected. -dayroom border of drop ceiling okay -bathrooms okay -conference room border of drop ceiling okay -captain office border of drop ceiling okay -covered patio on W side okay -east patio/entrance okay -conference room okay
---	------	--

Informational:

3	Misc	Remove drop ceiling tiles for inspection 2nd floor -203 to be completed -202 okay -hall okay
---	------	--

- 213 close boxes and fill unused knockout.
- 212 okay
- 211 okay
- 210 okay
- 209 okay
- 205 okay
- 207 to be completed
- 208 okay
- hall duct work To be seal
- ceiling space above stair ok

Comments: