

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226232
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Robb Popp	Partial	Friday, February 02, 2024

Corrective Action Required:

1	Misc	<p>**Foundation stem walls: Complete</p> <p>**Stairwell and Elevator at existing:</p> <p>-3rd level walls</p> <p>**Addition Elevator:</p> <p>-Stem walls</p> <p>-1st level walls</p> <p>-2nd level walls</p> <p>**Addition Stairwell</p> <p>-1st level walls</p> <p>-2nd level walls</p> <p>**Columns</p> <p>-1st level columns complete</p> <p>-2nd level columns complete</p> <p>-3rd level: north (14) columns</p> <p>-Canopy pilasters at CB</p> <p>-Columns on existing rooftop: Complete</p> <p>**Decks</p>
---	------	---

-2nd level addition deck complete

Comments: