

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Kyle Beard	Partial	Monday, February 05, 2024

Informational:

1	Miscellaneous Correction	Erosion control is in place and needs to be maintained until full occupancy
---	--------------------------	---

Informational:

3	Miscellaneous Correction	Erosion control is in place at the time of TCO Full erosion control must be maintained until CofO
---	--------------------------	--

**Comments:**