## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRCOM20234052Address:150 NE TUDOR RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
Water Service Inspection		John Jackson	Partial	Monday, February 05, 2024
Informati	onal:			
1	Misc	<ul> <li>11/30/23 Thursday JMJ</li> <li>Contractor installed floor for backflow vault 11/29/23 Wednesday</li> <li>Today contractor began boring and installation of PVC encasement for the relocation of fire hydrant.</li> <li>Encasement under Schlotzsky's driveway entrance.</li> <li>12/04/23 Monday JMJ</li> <li>Contractor plans to continue the installation of 6" PVC water main through PVC encasement with boots at each ends. Contractor is trying to relocate hydrant. Hydrant will be out of service until new fire and water main are installed.</li> </ul>		
			e construction of 6" water as Il be used to separate exist	· ·
			relocated hydrant as-per pla over hydrant because it is n	

		12/15/23 Friday JMJ (Capital Builders) Contractor restarted the construction of fire main and poured backing blocks behind fire hydrant, & 6X6 Tee. The contractor backfilled 6" fire main also contractor began installation of backflow valves.
		12/20/23 Wednesday JMJ (Capital Builders) Contractor installed water line all the way into vault yesterday and sent pictures for verification.
Informa	itional:	
2	Misc	01/02/24 Friday JMJ (Capital Builders)
		Contractor chlorinated water main.
		01/05/24 Monday JMJ (Capital Builders) Contractor de-chlorinated water main.

Comments: