

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234721

Address: 2002 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822004 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822006 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822008 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Passed	Monday, February 05, 2024

Informational:

1 Misc

1-29-24 Dustin A, For units 2008,2006,2004 and 2002, Dw is formed and aggregate is compacted. Will need to maintain ada slopes through approach. Must apply white cure per city specs. Approved to pour
2-5-24 Dustin A, All four DWs are in . Forms are pulled and slopes are in compliance with city specs. Passed

Comments: