

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234777  
Address: 2615 SW BARLEY FIELD DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Passed	Tuesday, February 06, 2024

Informational:  
1 Misc 2-1-24 Dustin A, SW is formed and aggregate is compacted. Slopes are in compliance, Approved to pour, Will need white cure added per city city spec  
2-6-24 Dustin A, Sw is poured to city specs . Slopes are in compliance. Passed

**Comments:**