

February 1, 2024

Bill Fowler
3601 W 122nd Terrace
Leawood, KS 66209
Phone (913) 908-5363
bwfowler@me.com

**RE: TWIN VILLA – WOODLAND GLEN LOT 35
1437 & 1439 SW WINTHROP TERRACE
LEE'S SUMMIT, MO**

JOB #2024-0437

This letter is regarding City comments for the above-referenced project. The following is a list of structural comments with our response.

Comment #1: Identify location(s) of vertical supports and purlins. (IRC Section R802.4.5).

Response: Reference sheet S21 for location of purlins and roof framing plan sheet note 20. Reference note 14 on sheet S21 for support locations. Vertical supports for LVL ceiling beams are identified on the Ceiling Framing Plan on sheet S20.

If there are any questions, please call.

Sincerely,

Eddie Phillips, P.E.
Principal

