

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215800
Address: 1600 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Mitchell Schwarz	Failed	Wednesday, February 07, 2024

Corrective Action Required:

1 Misc

-Remove outdoor restroom from street

Corrective Action Required:

2 DCM3 ESC
REQUIRED 2 DAY

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.

Corrective Action Required:

3 DCM2 ESC
DEFICIENT
INSTALLATION

DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. MAINTAIN EROSION CONTROL AROUND LOT. REPAIR DOWNED SILT FENCE AND REPLACE WHERE MISSING

Comments: