

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234774

Address: 3734 SW MARYVILLE PL, LEES SUMMIT, MO 640823736 SW MARYVILLE PL, LEES SUMMIT, MO  
640823738 SW MARYVILLE PL, LEES SUMMIT, MO 640823740 SW MARYVILLE PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Kyle Beard	Partial	Thursday, February 08, 2024

Informational:

1	Miscellaneous Correction	3740 Fire separation wall passed screw pattern
---	-----------------------------	---

3738  
Fire separation wall on both sides passed screw pattern

This is a partial pass only. Other units will be scheduled at a later date

**Comments:**