

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236587  
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sewer Service Inspection - R</b>	Khanh Nguyen	Not Ready	Thursday, February 08, 2024

Corrective Action Required:

1	Misc	<b>**REQUESTED INSPECTION(S) DENIED DUE TO LACK OF EROSION CONTROL. EROSION CONTROL SHALL BE INSTALLED ALONG THE DISTURBED SOIL TO PROTECT THE CREEK FROM SILT RUNOFF</b>
		<b>**FOOTING WAS NOT INSPECTED BY CITY. SUBMIT FOOTING APPROVAL FROM ENGINEER</b>

**Comments:**