

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234774

Address: 3734 SW MARYVILLE PL, LEES SUMMIT, MO 640823736 SW MARYVILLE PL, LEES SUMMIT, MO
640823738 SW MARYVILLE PL, LEES SUMMIT, MO 640823740 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Passed	Friday, February 09, 2024

Informational:

1	Miscellaneous Correction	3740 Fire separation wall passed screw pattern
---	-----------------------------	---

3738
Fire separation wall on both sides passed screw pattern

This is a partial pass only. Other units will be scheduled at a later date

Informational:

2	Miscellaneous Correction	All units passed for screw pattern
---	-----------------------------	------------------------------------

Comments: