

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230682  
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sanitary - Material Verification</b>	Patrick Schonfeldt	Partial	Monday, February 12, 2024

Informational:	
1 Misc	2-12-24 PS Verified that approved materials for creek crossing at 21+00, 10" Certa-Flo restrained joint line and max adaptors for connecting unrestrained sections to restrained sections per revised details

**Comments:**