



- EXISTING 720-101
NON - STANDARD KCPL MANHOLE WITH NO FLARES. HAD BEEN VERIFIED IN THE FIELD 2'-6" EMPTY CONDUIT EXISTS FROM MANHOLE TO BREAKER.
- EXISTING 720-105
NON - STANDARD KCPL MANHOLE WITH NO FLARES. BORE HOLE ON EAST SIDE OF MANHOLE FOR CONDUIT TO MH1449731
- INSTALL 720-105
CAST IN-PLACE DUE TO T-LINE 12' X 12' TWO FLARE
- INSTALL 720-105
12' X 12' TWO FLARE
- INSTALL 720-105
12' X 12' TWO FLARE
- INSTALL 720-105
CAST IN-PLACE 12' X 12' TWO FLARE

- POS 5 TO POS 6: 1 - 6" CONDUIT
- POS 6 TO POS 7: 8 - WAY 6" DUCT
- POS 7 TO POS 8: 8 - WAY 6" DUCT
- POS 8 TO POS 9: 8 - WAY 6" DUCT
- POS 9 TO POS 10: 4 - WAY 6" DUCT (BORE UNDER RAILROAD TRACKS)
- POS 10 TO POS 11: 4 - WAY 6" DUCT
- POS 11 TO POS 12: 4 - WAY 6" CONDUIT
- POS 12 TO POS 13: 4 - WAY 6" DUCT
- POS 13 TO POS 14: 4 - WAY 6" DUCT
- POS 14 TO POS 15: 1 - WAY 6" CONDUIT
- POS 6 TO POS 3: 1 - WAY 6" CONDUIT
- POS 3 TO POS 17: 1 - WAY 6" CONDUIT
- POS 3 TO POS 16: 1 - WAY 6" CONDUIT
- POS 11 TO POS 18: 1 - WAY 6" CONDUIT
- POS 9 TO POS 2: 1 - WAY 6" CONDUIT

BUILT AS DESIGNED
CHANGES AS NOTED
LEADERMAN
DATE
DATE

<p>Know what's below. Call before you dig.</p>	<p>KCPL CONTACTS</p> <p>PROJECT DESIGNER: JCASEY</p> <p>OFFICE: JERRY CASEY 9130794215</p> <p>OTHER: _____</p> <p>OTHER: _____</p>	<p>TITLE: KCPL</p> <p>PR.#: 50016392</p> <p>WWW: 90478</p> <p>ADDRESS: CHIPMAN ROAD</p> <p>CITY: SEB'S SUMMIT</p> <p>COUNTY: JA STATE: MD</p> <p>RCV: _____ JOB TYPE: F1100D</p>	<p>SEC: 31 TWP: 48N RANGE: 31W TAX DIST: _____</p> <p>REV. DATE BY CHECKED APPROVED</p> <p>DESIGNED BY: JCASEY</p> <p>DATE: 11/29/2011</p> <p>DWG FILE #: B112814</p>
	<p>EXISTING: _____</p> <p>INSTALL: _____</p> <p>REMOVE: _____</p> <p>NO COPY: _____</p>	<p>KCPL</p> <p>LEADS CENTER</p> <p>DESIGNED BY: JCASEY</p> <p>DATE: 11/29/2011</p> <p>DWG FILE #: B112814</p>	