

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234858  
Address: 2147 NW KILLARNEY LN, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:            | Inspector: | Outcome: | Date:                     |
|------------------------|------------|----------|---------------------------|
| <b>Erosion Control</b> | Robb Popp  | Failed   | Monday, February 12, 2024 |

Corrective Action Required:

|   |                                       |   |
|---|---------------------------------------|---|
| 2 | DCM2 ESC<br>DEFICIENT<br>INSTALLATION | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS<br>UNTIL ADEQUATE EROSION CONTROL PROVIDED.<br><br>-Maintain silt fence and clean debris from street |
|---|---------------------------------------|---|

**Comments:**