CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234205

Address: 1441 SW WINTHROP TER, LEES SUMMIT, MO 640811443 SW WINTHROP TER, LEES SUMMIT, MO

64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Alex Fischer Failed Tuesday, February 13,

Residential 2024

Corrective Action Required:

1 Misc -CSPF straps not connected all the way to top plate at garage both units

-Supply duct in rec room choked off on both units

-North wall basement fire block every 10 feet (1443)

-Incorrect grounding acorns at ufer (1443)

-Address gap above island where joist meets hip (1441)

-Electrical service entrance, ground wire and coax cable for unit 1443 needs

fire caulking at joist penetration

-East wall basement needs vertical fire blocking between two bed rooms

some where at or near shower area (1441)
-No bocca plates basement bathroom (1441)

-Secure wires at chase on both units

-Incomplete soffit (1441)

-Fire block above I-beam basement (1441)

Comments: