

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225393
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|---------------------------------|
| Underground Electrical Inspection - Commercial | Mitchell Schwarz | Passed | Wednesday, February 14, 2024 |

Informational:

| | | |
|---|-----------------------------|--|
| 1 | Miscellaneous Correction | Inspected areas Underground for the generator passed. Underground from the transformer to the generator passed. underground conduit for light poles S side of building. Underground conduit for non permanent power Underground conduit between both West most light pole bases |
|---|-----------------------------|--|

Comments: