

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225393
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mitchell Schwarz	Passed	Wednesday, February 14, 2024

Corrective Action Required:

1	Misc	First layer, screw pattern walls under stairs Fire caulking directly under stairs 1st, 2nd and 3rd layer under stairs ceiling 1st layer elevator **Correction: Face layer of elevator wall-mud&tape gaps
---	------	---

Comments: