

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20225614
Address: 4101 NE PORT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Khanh Nguyen	Partial	Thursday, February 15, 2024

Informational:	
1 Misc	Preliminary walkthrough of the 1st floor. Framing generally ok; however, install studs per plan at NE and SE corners and fasten partition panel at laps @ 6" oc

Comments: