

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236539
Address: 3735 SW CLAYTON PL, LEES SUMMIT, MO 640823737 SW CLAYTON PL, LEES SUMMIT, MO
640823739 SW CLAYTON PL, LEES SUMMIT, MO 640823733 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Kyle Beard	Failed	Friday, February 16, 2024

Corrective Action Required:

1	Miscellaneous Correction	Drain tile must have a minimum of 2 inches of crushed stone or gravel under it according to the approved plans under foundation drain and raised slab detail
		Remove all lumber from forms in contact with the earth R408.5

Comments: