CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20225393 Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Storm Sewer Construction Inspection	Bobby Richest	Passed	Friday, February 16, 2024
Informational:			
1 Misc	 6-30-23 BR 10' of storm sewer was install on east side of building. 7-11-23 BR 60' of storm sewer was installed on east side as well 100' storm sewer was installed on the south side of the buildin 7-20-23 BR Sand trap line on west side of building connect to storm sewer 8-29-23 BR 12" storm sewer was in installation from new manhole 1000.JB to (1001. AI) 30" inlet with dome grate. 		
	8-31-23 BR 12" Storm sewer was installed from (1001.AI) 30" inlet with dome gate to(1003.CI) 2"x3" curb inlet.		
	2-16-24 Dustin A, Passed per BR		

Comments: