

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232356

Address: 457 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081459 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081461 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081463 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081465 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081467 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081455 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	Khanh Nguyen	Failed	Friday, February 16, 2024

Corrective Action Required:

1	Misc	Test pressure not holding for units 463 and 467. All other units are OK
---	------	---

Comments: