	SCHEDULE OF SPECIAL INSPECTION SERVICES							
PROJECT								
MATERIAL / ACTIVITY	CEDVICE	V/N	APPLICABLE					
MATERIAL / ACTIVITY 1704.2.5.1 Inspection of	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED			
Fabricators								
Verify fabrication/quality control procedures	In-plant review (3)	N	Periodic					
1705.1.1 Special Cases (work unusual in nature, including but not limited to alternative materials and systems, unusual design applications, materials and systems with special manufacturer's requirements)	Submittal review, shop (3) and/or field inspection	N						
1705.2 Steel Construction								
Fabricator and erector documents (Verify reports and certificates as listed in AISC 360, chapter N, paragraph 3.2 for compliance with construction documents)	Submittal Review	Υ	Each submittal					
Material verification of structural steel	Shop (3) and field inspection	Υ	Periodic					
Embedments (Verify diameter, grade, type, length, embedment. See 1705.3 for anchors)	Field inspection	Υ	Periodic					
Verify member locations, braces, stiffeners, and application of joint details at each connection comply with construction documents	Field inspection	Υ	Periodic					
5. Structural steel welding:								
Inspection tasks Prior to Welding (Observe, or perform for each welded joint or member, the QA tasks listed in AISC 360, Table N5.4-1)	Shop (3) and field inspection	Υ	Observe or Perform as noted (4)					
b. Inspection tasks During Welding (Observe, or perform for each welded joint or member, the QA tasks listed in AISC 360, Table N5.4-2)	Shop (3) and field inspection	Υ	Observe or Perform as noted (4)					
c. Inspection tasks After Welding (Observe, or perform for each welded joint or member, the QA tasks listed in AISC 360, Table N5.4-3)	Shop (3) and field inspection	Y	Observe or Perform as noted (4)					
d. Nondestructive testing (NDT) of welded joints: see Commentary								
Complete joint penetration groove welds 5/16" or greater in risk category III or IV	Shop (3) or field ultrasonic testing - 100%	N	Periodic					
Complete joint penetration groove welds 5/16" or greater in risk category II	Shop (3) or field ultrasonic testing - 10% of welds minimum	N	Periodic					
Welded joints subject to fatigue when required by AISC 360, Appendix 3, Table A-3.1	Shop (3) or field radiographic or Ultrasonic testing	N	Periodic					
Fabricator's NDT reports when fabricator performs NDT	Verify reports	N	Each submittal (5)					
6. Structural steel bolting:	Shop (3) and field inspection							
a. Inspection tasks Prior to Bolting (Observe, or perform tasks for each bolted connection, in accordance with QA tasks listed in AISC 360, Table N5.6-1)		Υ	Observe or Perform as noted (4)					
b.Inspection tasks During Bolting (Observe the QA tasks listed in AISC 360, Table N5.6-2)		Υ	Observe (4)					

	SCHEDULE OF SPEC	IAL IN	SPECTION SE	RVICES			
PROJECT							
				E TO THIS PRO			
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED		
Pre-tensioned and slip-critical joints							
a) Turn-of-nut with matching		N	Periodic				
markings b) Direct tension indicator		N	Periodic				
c) Twist-off type tension control		1 1		1			
bolt		N	Periodic				
d) Turn-of-nut without matching markings		N	Continuous				
e) Calibrated wrench		N	Continuous				
2) Snug-tight joints		N	Periodic				
c. Inspection tasks After Bolting (Perform tasks for each bolted connection in accordance with QA tasks listed in AISC 360, Table N5.6- 3)		Y	Perform (4)				
1705.2.2 Cold-formed Steel Deck							
Inspection of cold-formed steel floor and roof deck in accordance with the quality assurance inspection requirements of SDI QA/QC.	Field inspection	N	Periodic				
1705.2.3 Open-Web Steel Joists and Joist Girders							
Installation of open-web steel joists		N					
and joist girders: a. End Connections		N	Periodic				
b. Bridging - horizontal or diagonal		N	1 Chodic				
5 5			Davida dia				
Standard bridging Bridging that differs from the SJI specifications listed in Section 2207.1		N	Periodic Periodic				
1705.2.4 Cold-formed steel trusses spanning 60 feet or greater							
Verify temporary and permanent restraint/bracing are installed in accordance with the approved truss submittal package	Field inspection	N	Periodic				
1705.3 Concrete Construction							
1. Inspection of reinforcing steel and prestressing steel installation	Shop (3) and field inspection	Υ	Periodic				
Reinforcing bar welding A. Verify weldability of reinforcing bars other than ASTM A706	Field inspection	N	Periodic				
b. Inspect single pass fillet welds, maximum 5/16"	Field inspection	N	Periodic				
c. Inspect all other welds.	Field inspection	N	Continuous				
3. Inspection of anchors cast in concrete	Shop (3) and field inspection	Υ	Periodic				
4. Inspect anchors post-installed in hardened concrete members		Υ					
a. Adhesive anchors installed in horizontally or upwardly inclined orientations to resist sustained tension loads	Field inspection	Y	Continuous				
b. Mechanical anchors and adhesive anchors not defined in 4.a	Field inspection	Υ	Periodic				
5. Verify use of approved design mix	Shop (3) and field inspection	Υ	Periodic				

	SCHEDULE OF SPECIAL INSPECTION SERVICES					
PROJECT						
MATERIAL / ACTIVITY	SERVICE	Y/N	APPLICABLE EXTENT	ROJECT DATE COMPLETED		
6. Fresh concrete sampling, perform slump and air content tests and determine temperature of concrete	Shop (3) and field inspection	Y	Continuous	AGENT*	DATE COMPLETED	
7. Inspection of concrete and shotcrete placement for proper application techniques	Shop (3) and field inspection	Y	Continuous			
Inspection for maintenance of specified curing temperature and techniques	Shop (3) and field inspection	Y	Periodic			
9. Inspection of prestressed concrete:	Shop (3) and field inspection	N				
a. Application of prestressing force		N	Continuous			
b. Grouting of bonded prestressing tendons		N	Continuous			
10. Erection of precast concrete members		N				
a. Inspect in accordance with construction documents	Field inspection	N	In accordance with construction documents			
b. Perform inspections of welding and bolting in accordance with Section 1705.2	Field inspection	N	In accordance with Section 1705.2			
11. Verification of in-situ concrete strength, prior to stressing of tendons in post tensioned concrete and prior to removal of shores and forms from beams and structural slabs	Review field testing and laboratory reports	N	Periodic			
12. Inspection of formwork for shape, location and dimensions	Field inspection	N	Periodic			
1705.4 Masonry Construction						
(A) Level 1, 2 and 3 Quality Assurance:						
Verify compliance with approved submittals	Field Inspection	Υ	Periodic			
(B) Level 2 Quality Assurance:						
Verification of fm and f _{AAC} prior to construction	Testing by unit strength method or prism test method	Υ	Periodic			
(C) Level 3 Quality Assurance:						
Verification of fm and f _{AAC} prior to construction and for every 5,000 SF during construction	Testing by unit strength method or prism test method	N	Periodic			
Verification of proportions of materials in premixed or preblended mortar, prestressing grout, and grout other than self-consolidating grout, as delivered to the project site	Field inspection	N	Continuous			
(D) Levels 2 and 3 Quality Assurance:						

	SCHEDULE OF SPE	CIAL IN	SPECTION SER	RVICES				
PROJECT								
MATERIAL / ACTIVITY	SERVICE	Y/N	APPLICABLE EXTENT	TO THIS PI AGENT*	ROJECT DATE COMPLETED			
MATERIAL / ACTIVITY 1. Verification of Slump Flow and Visual Stability Index (VSI) of self-consolidating grout as delivered to the project	Field testing	Y	Continuous	AGENT	DATE COMPLETED			
Verify placement of masonry units	Field Inspection	Υ	Periodic					
Verify proportions of site-mixed mortar, grout and prestressing grout for bonded tendons	Field Inspection	Υ	Periodic					
Verify grade, type, and size of reinforcement, connectors, anchor bolts, and prestressing tendons and anchorages	Field Inspection	Y	Periodic					
Verify construction of mortar joints	Field Inspection	Υ	Periodic					
Verify placement of reinforcement, connectors, and prestressing tendons and anchorages	Field Inspection	Y	Level B - Periodic					
		N	Level C - Continuous					
7. Verify placement of prestressing tendons and anchorages	Field Inspection	N	Periodic					
Verify grout space prior to grouting	Field Inspection	Y N	Level B - Periodic Level C - Continuous					
Verify placement of grout and prestressing grout for bonded tendons	Field Inspection	N	Continuous					
Verify size and location of structural masonry elements	Field Inspection	Υ	Periodic					
11. Verify type, size, and location of anchors, including details of anchorage of masonry to structural members, frames, or other construction.	Field inspection	Y	Level B - Periodic					
		N	Level C - Continuous					
12. Verify welding of reinforcement (see 1705.3.1)	Field inspection	N	Continuous					
13. Verify preparation, construction, and protection of masonry during cold weather (temperature below 40°F) or hot weather (temperature above 90°F)	Field inspection	Y	Periodic					
14. Verify application and measurement of prestressing force	Field Inspection	N	Continuous					
15. Verify placement of AAC masonry units and construction of thin-bed mortar joints (first 5000 SF of AAC masonry)	Field inspection	N	Continuous					
16. Verify placement of AAC masonry units and construction of thin-bed mortar joints (after the first 5000 SF of AAC masonry)	Field inspection	N	Level B - Periodic					
		N	Level C - Continuous					
17. Verify properties of thin-bed mortar for AAC masonry (first 5000 SF of AAC masonry)	Field inspection	N	Continuous					

	SCHEDULE OF SPEC	CIAL IN	SPECTION SER	RVICES				
PROJECT								
MATERIAL / ACTIVITY	055)//05	201	APPLICABLE					
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED			
18. Verify properties of thin-bed mortar for AAC masonry (after the first 5000 SF of AAC masonry)	Field inspection	N	Level B - Periodic					
		N	Level C - Continuous					
19. Prepare grout and mortar specimens	Field testing	Υ	Level B - Periodic					
		N	Level C - Continuous					
20. Observe preparation of prisms	Field inspection	Υ	Level B - Periodic					
		N	Level C - Continuous					
1705.5 Wood Construction								
Inspection of the fabrication process of wood structural elements and assemblies in accordance with Section 1704.2.5	In-plant review (3)	Y	Periodic					
For high-load diaphragms, verify grade and thickness of structural panel sheathing agree with approved building plans	Field inspection	N	Periodic					
For high-load diaphragms, verify nominal size of framing members at adjoining panel edges, nail or staple diameter and length, number of fastener lines, and that spacing between fasteners in each line and at edge margins agree with approved building plans	Field inspection	N	Periodic					
4. Metal-plate-connected wood trusses with overall height 60 inches or greater: verify permanent individual truss member restraint/bracing is installed in accordance with the approved truss submittal package.	Field inspection	N	Periodic					
Metal-plate-connected wood trusses spanning 60 feet or greater: verify temporary and permanent restraint/bracing are installed in accordance with the approved truss submittal package	Field inspection	N	Periodic					
1705.6 Soils								
Verify materials below shallow foundations are adequate to achieve the design bearing capacity.	Field inspection	Y	Periodic					
Verify excavations are extended to proper depth and have reached proper material.	Field inspection	Υ	Periodic					
Perform classification and testing of controlled fill materials.	Field inspection	Υ	Periodic					
Verify use of proper materials, densities, and lift thicknesses during placement and compaction of controlled fill	Field inspection	Υ	Continuous					
Prior to placement of compacted fill, inspect subgrade and verify that site has been prepared properly	Field inspection	Υ	Periodic					
1705.7 Driven Deep Foundations								
Verify element materials, sizes and lengths comply with requirements	Field inspection	N	Continuous					
Determine capacities of test elements and conduct additional load tests, as required	Field inspection	N	Continuous					

	SCHEDULE OF SPECIAL INSPECTION SERVICES							
PROJECT								
MATERIAL / ACTIVITY	CEDVICE	V/N	APPLICABLE TO THIS PROJECT Y/N EXTENT AGENT* DATE COMPLETED					
MATERIAL / ACTIVITY 3. Inspect driving operations and maintain complete and accurate	SERVICE Field inspection	Y/N N	Continuous	AGEN1"	DATE COMPLETED			
records for each element 4. Verify placement locations and plumbness, confirm type and size of hammer, record number of blows per foot of penetration, determine required penetrations to achieve design capacity, record tip and butt elevations and document any damage to foundation element	Field inspection	N	Continuous					
5. For steel elements, perform additional inspections per Section 1705.2	See Section 1705.2	N	See Section 1705.2					
6. For concrete elements and concrete- illed elements, perform additional nspections per Section 1705.3	See Section 1705.3	N	See Section 1705.3					
 For specialty elements, perform additional inspections as determined by the registered design professional in responsible charge 	Field inspection	N	In accordance with construction documents					
Perform additional inspections and tests in accordance with the construction documents	Field Inspection and testing	N	In accordance with construction documents					
1705.8 Cast-in-Place Deep Foundations								
naintain complete and accurate records for each element	Field inspection	N	Continuous					
Verify placement locations and plumbness, confirm element diameters, bell diameters (if applicable), lengths, embedment into bedrock (if applicable) and adequate end-bearing strata capacity. Record concrete or grout volumes	Field inspection	N	Continuous					
For concrete elements, perform tests and additional special inspections in accordance with Section 1705.3	See Section 1705.3	N	See Section 1705.3					
Perform additional inspections and tests in accordance with the construction documents	Field Inspection and testing	N	In accordance with construction documents					
1705.9 Helical Pile Foundations								
Verify installation equipment, pile dimensions, tip elevations, final depth, final installation torque and other data as required.	Field inspection	N	Continuous					
Perform additional inspections and tests in accordance with the construction documents	Field Inspection and testing	N	In accordance with construction documents					
1705.11.1 Structural Wood Special Inspections For Wind Resistance								
Inspection of field gluing operations felements of the main windforce- esisting system	Field inspection	N	Continuous					
2. Inspection of nailing, bolting, anchoring and other fastening of components within the main windforce- resisting system	Shop (3) and field inspection	N	Periodic					

	SCHEDULE OF SPEC	IAL IN	ISPECTION SER	RVICES	
PROJECT					
		ROJECT			
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED
1705.11.2 Cold-formed Steel					
Special Inspections For Wind					
Resistance Inspection during welding operations					
of elements of the main windforce-	Shop (3) and field inspection	N	Periodic		
esisting system	errop (e) and note inoperation		1 Ollowio		
2.Inspections for screw attachment,					
polting, anchoring and other fastening of components within the main	Shop (3) and field inspection	N	Periodic		
windforce-resisting system					
3 ,					
1705.11.3 Wind-resisting					
Components	Ob (0) d fold in tion	NI.	D. d. d.		
Roof cladding and connections Wall cladding and connections	Shop (3) and field inspection Shop (3) and field inspection	N N	Periodic Periodic		
1705.12.1 Structural Steel	Shop (3) and held inspection	IN	1 CHOUIC		
Special Inspections for Seismic					
Resistance					
Inspection of structural steel in	Ob (0) d f 1 ''	١	In accordance with		
accordance with AISC 341	Shop (3) and field inspection	N	AISC 341		
1705.12.2 Structural Wood					
Special Inspections for Seismic					
Resistance					
Inspection of field gluing operations					
of elements of the seismic-force	Field inspection	N	Continuous		
resisting system 2. Inspection of nailing, bolting,					
anchoring and other fastening of					
elements within the seismic-force-	Shop (3) and field inspection	N	Periodic		
resisting system					
1705.12.3 Cold-formed Steel					
Light-Frame Construction					
Special Inspections for Seismic					
Resistance					
Inspection during welding operations					
of elements of the seismic-force-	Shop (3) and field inspection	N	Periodic		
resisting system	Shop (3) and held inspection	IN	renouic		
2. Inspections for screw attachment,					
bolting, anchoring and other fastening of elements within the seismic-force-	Shop (3) and field inspection	N	Periodic		
resisting system					
3 ,					
1705.12.4 Designated Seismic					
Systems Verification					
man and and spaint, that the account					
Inspect and verify that the component	Field increation	N N	Periodic		
abel, anchorage or mounting conforms of the certificate of compliance	Field inspection	N	renodic		
and solumetre of compliance					
1705.12.5 Architectural					
Components Special Inspections					
for Seismic Resistance					
. Inspection during the erection and					
astening of exterior cladding and	Field inspection	N	Periodic		
nterior and exterior veneer	'	<u> </u>			
2. Inspection during the erection and					
astening of interior and exterior	Field inspection	N	Periodic		
onbearing walls					

SCHEDULE OF SPECIAL INSPECTION SERVICES					
PROJECT					
			APPLICABLE		
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED
Inspection during anchorage of access floors	Field inspection	N	Periodic		
1705.12.6 Plumbing, Mechanical and Electrical Components Special Inspections for Seismic Resistance					
Inspection during the anchorage of electrical equipment for emergency or standby power systems	Field inspection	N	Periodic		
Inspection during the anchorage of other electrical equipment	Field inspection	N	Periodic		
Inspection during installation and anchorage of piping systems designed to carry hazardous materials, and their associated mechanical units	Field inspection	N	Periodic		
Inspection during the installation and anchorage of HVAC ductwork that will contain hazardous materials	Field inspection	N	Periodic		
Inspection during the installation and anchorage of vibration isolation systems	Field inspection	N	Periodic		
 Inspection of clearances of installed mechanical and electrical equipment where automatic fire sprinkler systems are installed in SDC C, D, E, or F structures. 	Field inspection	N	Periodic		
1705.12.7 Storage Racks Special Inspections for Seismic Resistance					
Inspection during the anchorage of storage racks 8 feet or greater in height	Field inspection	N	Periodic		
1705.12.8 Seismic Isolation Systems					
Inspection during the fabrication and installation of isolator units and energy dissipation devices used as part of the seismic isolation system	Shop and field inspection	N	Periodic		
1705.13.1 Structural Steel Testing and Qualification for Seismic Resistance					
Test in accordance with the quality assurance requirements of AISC 341	Shop (3) and field testing	N	Per AISC 341		
1705.13.2 Seismic Certification of Nonstructural Components					
Review certificate of compliance for seismic qualification.	Certificate of compliance review	N	Each submittal		

	SCHEDULE OF SPEC	IAL IN	ISPECTION SEI	RVICES				
PROJECT		.,						
	APPLICABLE TO THIS PROJECT							
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED			
1705.13.3 Designated Seismic								
Systems								
Review certificate of compliance for designated seismic system components.	Certificate of compliance review	N	Each submittal					
1705.13.4 Seismic Isolation								
Systems								
Test seismic isolation system in accordance with ASCE 7 Section 17.8	Prototype testing	N	Per ASCE 7					
1705.14 Sprayed Fire-resistant								
Materials								
Verify surface condition preparation of structural members	Field inspection	Υ	Periodic					
Verify application of sprayed fire- resistant materials	Field inspection	Υ	Periodic					
Verify average thickness of sprayed fire-resistant materials applied to structural members	Field inspection	Y	Periodic					
Verify density of the sprayed fire- resistant material complies with approved fire-resistant design	Field inspection and testing	Y	Per IBC Section 1705.14.5					
Verify the cohesive/adhesive bond strength of the cured sprayed fire- resistant material	Field inspection and testing	Y	Per IBC Section 1705.14.6					
1705.15 Mastic and Intumescent Fire-Resistant Coatings								
Inspect mastic and intumescent fire- resistant coatings applied to structural elements and decks	Field inspection	N	Periodic					
1705.16 Exterior Insulation and Finish Systems (EIFS)								
In Verify materials, details and installations are per the approved construction documents	Field inspection	N	Periodic					
Inspection of water-resistive barrier over sheathing substrate	Field inspection	N	Periodic					
1705.17 Fire-Resistant								
Penetrations and Joints								
Inspect penetration firestop systems	Field testing	Υ	Per ASTM E2174					
Inspect fire-resistant joint systems	Field testing	Υ	Per ASTM E2393					

PROJECT					
			APPLICAB	LE TO THIS PRO	JECT
MATERIAL / ACTIVITY	SERVICE	Y/N	EXTENT	AGENT*	DATE COMPLETED
705.18 Smoke Control Systems					
. Leakage testing and recording of levice locations prior to concealment	Field testing	Y	Periodic		
2. Prior to occupancy and after ufficient completion, pressure lifference testing, flow measurements, and detection and control verification	Field testing	Y	Periodic		
*INSPECTION AGENTS FIRM			ADDRESS		TELEPHONE NO.
2. 3.					

- 3. Special Insepctions as required by Section 1704.2.5 are not required where the fabricator is approved in accordance with IBC Section 1704.2.5.1
- 4. Observe on a random basis, operations need not be delayed pending these inspections. Perform these tasks for each welded joint, bolted connection, or steel element.
- 5. NDT of welds completed in an approved fabricator's shop may be performed by that fabricator when approved by the AHJ. Refer to AISC 360, N6.

Are Requirements for Seismic Resistance included in the Statement of Special Inspections? Are Requirements for Wind Resistance included in the Statement of Special Inspections?

Yes X No Yes X No

DATE: 2/8/2024

ACEC/SEAOG SI GL 01 - 12 B10 of B10