

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231596
Address: 1121 SW CORINTHIAN LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, February 20, 2024

Corrective Action Required:

1	Misc	-update plans to show attic storage space above primary bedroom closet -porch and patios covered could not inspect -address holes drilled for pex in joist closer than 2" to each other above bed 3 -missing lvl above garage plans call for 3 (you have 2) -upload 3rd party suspended slab inspection
---	------	---

OK TO INSULATE

Comments: