

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20225681
Address: 2405 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Dustin Agcopra	Failed	Tuesday, February 20, 2024

Informational:	
1 Misc	2-7-24 Dustin A, DW is formed and aggregate is compacted. Approved to pour. 2-20-24 Dustin A, Dw is poured. Right panel does not meet city specs, Slopes are almost 3 percent. fail

Comments: