

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20220168  
Address: 2010 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, February 20, 2024

Corrective Action Required:

1	Misc	Pay all fees -sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of sod -obtain issued lawn irrigation permit -safety glazing required on basement windows less than 18" from floor -deck post to beam connection to be to code see 507.5.1 of 2018 IRC
---	------	---

**Comments:**