

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235728

Address: 3726 SW MARYVILLE PL, LEES SUMMIT, MO 640823728 SW MARYVILLE PL, LEES SUMMIT, MO
640823730 SW MARYVILLE PL, LEES SUMMIT, MO 640823722 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Tuesday, February 20, 2024

Corrective Action Required:

1	Miscellaneous Correction	3722 SW Maryville rated assembly
		3726
		Roof sheathing above bathroom north wall is damaged
		3730
		Roof sheathing above HVAC chase is damaged
		Garage north wall is missing Fire blocking in the upper 1/3 wall
		All units need to be fire blocked sealed in stairwell separating floors

Comments: