

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Patrick Schonfeldt	Failed	Wednesday, February 21, 2024

Corrective Action Required:

2	Misc	2-21-24 PS Provide erosion control protection at storm inlets as discussed on east side inlet at creek and on inlet on south end against 150 highway to protect from silt entering storm system. Provide silt fence around soils pile south end where new sanitary/storm being installed if it is expected to be there for longer duration that completion of sanitary and storm lines currently being installed.
---	------	---

Comments: