



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20113089, Building Permit - Commercial
Address: 930 NW BLUE PKWY, Unit:V, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Failed	Monday, August 15, 2011

Corrective Action Required
1 MISC

NORTH FACE OF SOUTH DEMISING WALL: UL465 RATED
ASSEMBLY REQUIRES SCREW PATTERN OF MAX 8" ON FRAMED
EDGES & 12" IN FIELD OF SHEET

Comments: