

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20234049

Address: 2210 SW OSAGE DR, LEES SUMMIT, MO 640822208 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Passed	Friday, February 23, 2024

Informational:

1	Misc	2-8-24 Dustin A, This is for 2210 and 2208, SW is formed. Aggregate is compacted, slopes are correct. There is a existing panel that is cracked on 2208 that needs to be replaced and there is a chipped panel on 2210 that will need to be replaced. 2-22-24 Dustin A, No progress 2-23-24 Dustin A,SW has been replaced. Passed
---	------	---

Comments: