

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234049

Address: 2210 SW OSAGE DR, LEES SUMMIT, MO 640822208 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Dustin Agcopra	Partial	Thursday, February 22, 2024

Informational:

1	Misc	2-8-24 Dustin A, This is for 2210 and 2208, SW is formed. Aggregate is compacted, slopes are correct. There is a existing panel that is cracked on 2208 that needs to be replaced and there is a chipped panel on 2210 that will need to be replaced. 2-22-24 Dustin A, No progress 2-23-24 Dustin A,SW has been replaced. Passed
---	------	---

**Comments:**