

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20230057

Address: 451 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081443 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081445 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081447 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081449 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081453 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081441 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Shawn Hoffman	Partial	Friday, February 23, 2024

Corrective Action Required:

1	Misc	**UNIT SCREW PATTERN ON DEMISE WALLS 441 OK 443 OK 445 OK 447 OK 449 - more screws needed at kitchen stove wall - add screws second to third floor stairs 451 NOT COMPLETE 453 NOT COMPLETE
---	------	---

Comments: