

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236587  
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Khanh Nguyen	Failed	Monday, February 26, 2024

Corrective Action Required:

1	Misc	-Support piping to structural slab every 4 ft -Vent the NE bathroom per code. Move the 3" waste stack connection min 30" f ft own stream of bath group plumbing -Install foundation drain tiles per code
---	------	---

**Comments:**